



FOR STORAGE CAPACITY REQUIREMENTS, REFER TO WATER STANDARD #1 AND STANDARD #6

WHEN MULTIPLE TANKS ARE UTILIZED TO ACHIEVE THE REQUIRED VOLUME OF WATER, THE CONNECTION BETWEEN THE TANKS SHALL BE BY AN APPROVED 4" DIAMETER WATER LINE

EMERGENCY WATER SUPPLY

FIRE SAFE EXHIBIT

**CAL FIRE/SLO COUNTY FIRE DEPARTMENT
PERMIT AND FIRE PREVENTION BUREAU**

635 N. Santa Rosa Avenue
San Luis Obispo, California 93405
Telephone (805) 543-4244 Fax (805) 543-4248

NOT TO SCALE

SCALE

3-3-08

REVISION DATE

2

EXHIBIT NO.