



TURNOUT

FOR DRIVEWAYS EXCEEDING 300 FEET IN LENGTH, A FIRE ENGINE TURNAROUND SHALL BE PROVIDED AT THE BUILDING SITE AND MUST BE LOCATED WITHIN 50 FEET OF THE STRUCTURE(S).
*

ANY DRIVEWAY EXCEEDING 800 FEET IN LENGTH AND LESS THAN 16 FEET IN WIDTH SHALL HAVE TURNOUTS CONSTRUCTED APPROXIMATELY EVERY FOUR 400 FEET ALONG THE ENTIRE LENGTH OF THE DRIVEWAY.

TURNOUTS

**CAL FIRE/SLO COUNTY FIRE DEPARTMENT
PERMIT AND FIRE PREVENTION BUREAU**

635 N. Santa Rosa Avenue
San Luis Obispo, California 93405
Telephone (805) 543-4244 Fax (805) 543-4248

FIRE SAFE EXHIBIT

1/16" = 1'-0"

SCALE

3-3-08

REVISION DATE

7

EXHIBIT NO.