

GATE

NOTE: GATE SHALL BE NO LESS THAN WIDTH OF THE ACCESS ROAD PLUS A 2 FT SHOULDER ON EACH SIDE.
ELECTRIC GATES SHALL BE OPERABLE AT ALL TIMES VIA BATTERY OR SOLAR POWER BACKUP.

GATES	FIRE SAFE EXHIBIT
CAL FIRE/SLO COUNTY FIRE DEPARTMENT *PERMIT AND FIRE PREVENTION BUREAU* *635 N. Santa Rosa Avenue* *San Luis Obispo, California 93405* *Telephone (805) 543-4244 Fax (805) 543-4248*	1/2" = 1'-0" SCALE 3-3-08 REVISION DATE 12 EXHIBIT NO.