



VERTICAL CLEARANCE TO FLAMMABLE VEGETATION:
13'-6" MINIMUM ABOVE ROADWAY SURFACE

HORIZONTAL CLEARANCE TO FLAMMABLE VEGETATION:
10' MINIMUM FROM EDGE OF ROADWAY

NOTES:

1. VEGETATION CLEAR ZONE REQUIREMENTS PER CALIFORNIA FIRE CODE, SECTION 304.1.2.
2. VEGETATION CLEAR ZONE APPLIES TO DRIVEWAYS, ACCESS ROADS, TURNOUTS, CUL-DE-SACS, HAMMERHEADS, FIRE HYDRANTS, AND ALL OTHER SITE IMPROVEMENTS WHERE CAL FIRE ACCESS IS REQUIRED.
3. DRIVEWAY AND ACCESS ROAD WIDTHS PER DWGS FP-7 AND FP-8.



COUNTY OF SAN LUIS OBISPO FIRE DEPARTMENT / CAL FIRE

VEGETATION CLEAR ZONE

Adopted: Aug. 2014	Scale: 1"=10'
Revised: Apr. 2017	Revision No.: 1
Drawing No.:	FP-6