

**Table 903.1 – Automatic Fire Sprinkler System Requirements for NEW CONSTRUCTION**

STRUCTURE TYPE	SPRINKLERS REQUIRED <sup>5</sup>	DESCRIPTION	SQUARE FOOTAGE <sup>1</sup>		REQUIREMENTS	EXCEPTIONS	EXAMPLES	MIN. DISTANCE BETWEEN STRUCTURES AND PROPERTY LINES(PL)
			MIN	MAX				
New Construction	Yes	New buildings including mobile homes and commercial coaches <sup>1</sup>	0		Throughout new buildings	See Footnote <sub>3,4</sub>	All new construction and dwellings	Per CBC, CRC
Residential Accessory Structure	Yes	Accessory structures as defined in CRC	1,000	3,000	No heating or cooling No living or sleeping spaces	See Footnote <sub>2</sub>	One story garage, workshop, studio, residential storage bldg	50 feet from PL, 30 feet from other structures
Agricultural Accessory Structure	Yes	Accessory to agricultural operation, livestock, crops. Agricultural operations in accordance with AG LUO & CBC definition	3,000	5,000	Primary usage must be 75% livestock or crops (affidavit required)	See Footnote <sub>2</sub>	One story barn or stables	100 feet from PL, 50 feet from other structures
Pole barn, Covered arena, Greenhouse	No	One story hay storage, covered riding arena, greenhouses	Unlimited if 60 feet on all sides per CBC		No employees, no public attendance and open on two or more sides	None	See description	100 feet from PL, 50 feet from other structures
Agricultural Exempt (no permit required)	No	LUO Ag Exempt & signed affidavit	0	3,000	Per Ag Exempt agreement (affidavit required)	See Title 19	Ag-Barn on Ag zoned land over 20 acres	100 feet from PL, 50 feet from other structures

**References:**

CRC: California Residential Code | CFC: California Fire Code | CBC: California Building Code | LUO: Land Use Ordinance (San Luis Obispo County)

**Footnotes:**

1. For the purpose of calculating square footage for the application of fire sprinkler requirements and fire flow requirements, the floor area shall include all combustible areas attached to the structure, including garages, patio covers, overhangs over 2 feet, covered walkways and decks.
2. Structures over the minimum square footage must meet **all of the above** table requirements **and all the following requirements:**
  - no conditioned or habitable space, ▪ no second stories (lofts 1/3 the floor area and open to below are allowed), ▪ minimum two exits including one pedestrian door (side hinge swinging door),
  - workshops or offices limited to 10% of floor area, ▪ dedicated fire water storage minimum of 5,000 gallons steel tank in full compliance with NFPA 1142(see fire safety plan) if there is no community provided fire hydrant within 500 ft., ▪ structure complies with the California Wildland Urban-Interface Ignition Resistant Construction Requirements, ▪ heat detectors installed in accordance with CBC linked to an audible bell mounted in the exterior of the structure. ▪ Cannot be used as a place of employment or for public assemblage/events. ▪ Cannot be used as a commercial building.
3. A single-story building or commercial coach where floor area does not exceed 1000 square feet and the occupancy is not a Group A, E Daycare, F1 Woodworking, R, Group H, Group I occupancy or any occupancy where cellulose nitrate film, pyroxylin plastics or any hazardous materials manufactured, stored or handled in quantities in excess of Tables in CBC, CFC or within Los Osos CSD and the fire flow from a hydrant is less than 750gpm at 20psi.
4. Mobile/manufactured or factory built homes or commercial coaches constructed or altered on or before March 12, 2011 which were not manufactured with automatic fire sprinklers.
5. Automatic Fire Sprinklers installed at exterior locations shall be approved corrosion resistant devices when environmental or operational conditions warrant

19.03.010 – 19.03.010

**Table 903.2 – Automatic Fire Sprinkler System Requirements for EXISTING CONSTRUCTION <sup>6</sup>**

OCCUPANCY OR STRUCTURAL MODIFICATION TYPE	SPRINKLERS REQUIRED <sup>3</sup>	DESCRIPTION	SQUARE FOOTAGE <sup>1</sup>	REQUIREMENTS	EXCEPTIONS	EXAMPLES
Alterations <sup>1</sup>	Yes...if	Alteration includes modifications to the structure	50% of existing floor area <sup>1</sup>	Alterations, additions and remodel square footage will be considered a combined and cumulative sum of floor area <sup>1</sup>	Repairs <sup>5</sup> and Footnote <sup>2</sup>	Interior remodels, Rehabilitation
Additions <sup>1</sup>	Yes...if	Additions cumulative from January 01, 2008 regardless of any change of ownership	1,000 sf or 50% of existing floor area <sup>1</sup>	Alterations, additions and remodel square footage will be considered a combined and cumulative sum of floor area <sup>1</sup>	none	Any addition
Additional Stories	Yes	Adding an additional story	Any	Attic/basement conversions over 1,000 sq.ft.	See Footnote <sup>4</sup>	Adding/convertng any habitable space above or below an existing structure
Sprinklered Buildings	Yes	Any occupancy	Any	Partially sprinklered structures not allowed	None	Any sprinklered building
Occupancy Classification Change	Yes	Change results in higher hazard or as deemed necessary by fire code official	Any	Hazard classification rating per Title 19 Table 3408.1.2	None	Detached garage, workshop or barn converted to conditioned space, guest house or commercial use
Hazardous Materials Inside buildings	Yes	Cellulose nitrate film or pyroxylin plastics or any hazardous materials manufactured, stored or handled in quantities in excess of Tables in CBC, CFC	Any	Building and any portion of a building must also include requirements as listed in CFC Chapter 5005.4	None	Any occupancy

**References:**

CRC: California Residential Code | CFC: California Fire Code | CBC: California Building Code |

**Footnotes:**

1. For the purpose of calculating square footage for the application of fire sprinkler requirements and fire flow requirements, the floor area shall include all combustible areas attached to the structure, including garages, patio covers, overhangs over 2 feet, and covered walkways and decks.
2. Alterations limited to **only** one of the following: replacement of exterior coverings and windows, roofing, electrical services, sewer laterals, retaining walls, or routine plumbing, electrical and mechanical repairs.
3. Automatic Fire Sprinklers installed at exterior locations shall be approved corrosion resistant devices when environmental conditions warrant.
4. A loft open to the floor below and no more than one third of the floor area of the room below is allowed to be added without triggering sprinklers.
5. REPAIR is the reconstruction or renewal for the purpose of maintenance. See 105.2.2 in Title 19.20.020 and the definition of alteration in the CBC.
6. Mobile/manufactured or factory built homes or commercial coaches constructed or altered on or before March 12, 2011 which were not manufactured with automatic fire sprinklers are not subject to fire sprinkler requirements.