



VERTICAL CLEARANCE TO FLAMMABLE VEGETATION
13'-6" MINIMUM ABOVE ROADWAY SURFACE

HORIZONTAL CLEARANCE TO FLAMMABLE VEGETATION:
10' MINIMUM FROM EDGE OF ROADWAY

NOTES:

1. VEGETATION CLEAR ZONE REQUIREMENTS PER CALIFORNIA FIRE CODE, SECTION 304.1.2.
2. VEGETATION CLEAR ZONE APPLIES TO DRIVEWAYS, ACCESS ROADS, TURNOUTS, CUL-DE-SACS, HAMMERHEADS, FIRE HYDRANTS, AND ALL OTHER SITE IMPROVEMENTS WHERE CAL FIRE ACCESS IS REQUIRED.
3. DRIVEWAY AND ACCESS ROAD WIDTHS PER DWGS FP-9 AND FP-10.



COUNTY OF SAN LUIS OBISPO FIRE DEPARTMENT / CAL FIRE

VEGETATION CLEAR ZONE

Revised:

July 2020

Drawing No.:

FP-12