



NOTES:

1. TURNOUTS REQUIRED FOR DRIVEWAYS EXCEEDING 150'.
2. TURNOUTS SHALL BE SPACED A MAXIMUM OF 400-FT APART.
3. MULTIPLE TURNOUTS MUST BE INTER-VISIBLE TO SATISFY SPACING REQUIREMENTS.
4. SEE SAN LUIS OBISPO COUNTY PUBLIC WORKS STANDARDS FOR GRADING SPECIFICS.



COUNTY OF SAN LUIS OBISPO FIRE DEPARTMENT / CAL FIRE
STANDARD DRIVEWAY TURN OUT

Revised:
APRIL 2023

Drawing No.: FP-5